



THIS PRINT IS OK TO BE BUILT

- NOTES:
1. HEAT LOSS WAS CALCULATED W/ R-19 INSULATION OR HEATED BSMT
 2. BUILDER IS RESPONSIBLE FOR PROVIDING A PROPERLY SIZED HEATING SYSTEM TO COVER A 102,000 BTU LOSS
 3. * - DENOTES ADDITIONAL COLUMN IN BASEMENT
 4. CLG BEAM OVER HALL TO BE 2-1 1/2" x 9 1/4" M.L.
 5. CLG BEAM OVER KITCHEN TO BE 4-1 1/2" x 11 1/4" M.L.

SIDING=30 SQ
SHINGLES=38 SQ



3236/2836 MOUNT AIRY 1st STORY FLOOR PLAN				
DRAWN BY: RM/SRR/NCL DGM	DATE: 11/05/02	SCALE: 1/4"=1'-0"	LAYER: SHL/FP1	FILE NO: A9692